


# Comanche Unit 3




# Comanche Project Milestones




# Pueblo's Water Supply

- Pueblo's water supply originates high in the Rocky Mountains above Leadville.
- Water from the high mountain watersheds flows into the Arkansas river.
- Pueblo Reservoir along with other reservoirs on the Arkansas ensures a long-term reliable water supply for Pueblo.




# Colorado Climate

- The continental divide which runs through the Rocky Mountains extends from the south to north boundaries of the state.
- Annual precipitation 17 inches
- Majority of the precipitation received by high peaks and mountain ranges.
- There are 4 major river systems that originate in Colorado: Colorado, Rio Grande, Arkansas, and the Platte.
- 40% of Colorado's area is made-up of the eastern high plains which has a semi-arid climate.
- The majority of Colorado's population lives on the eastern plains adjacent to the foothills.
- Multi-year drought is common to the eastern plains.



# Comanche's Water Supply


- 8,700 acre-feet/year for existing Units 1, 2
- Hybrid (Parallel) cooling utilized for Unit 3 reducing contract amount to 6,000 acre-feet/year
- Contract term through 2035 for Units 1, 2 with option to extend in 5-year increments starting in 2035
- Contract term for Unit 3 through 2060!



*Pueblo Board of Water Works  
Pueblo Reservoir*



# Map of Pueblo Area





# Raw Water Transport Line




# Proposed Low Water Use Plant


- **Installing low water use technologies ensures unit efficiency and water conservation**
  - Cooling tower and air cooling systems-design to operate in parallel
  - Comanche 3 will consume 4,750-5,500 acre feet annually (about 50% water savings)
  - Below 55°F - ACC alone can handle full heat rejection of plant.




# Design Day




# Dry Bulb – Frequency of Occurrence



# Wet Bulb – Frequency of Occurrence




## Dry Cooling ITD Trends





## Cooling System Comparison (Typical STG Backpressure Profile)



# Comanche Station Looking South



# Comanche Station Looking East





## Comanche Expansion Project





# Comanche Expansion Project




# Water Use Optimization



# Cooling Types


Wet Cooling

Dry Cooling




Surface Condenser

Wet Cooling Tower




Air Cooled Condenser

# Parallel Cooling Schematic





# Air Cooled Condenser





## Relative Annual Water Use Primary Cooling System Options

	<u>Plant Usage*</u>
<b>Wet Evaporative Cooling Tower</b>	<b>100%</b>
<b>Air Cooled Condenser</b>	<b>&lt; 5%</b>
<b>Wet/Dry PAC SYSTEM®</b>	<b>15 – 85% Range</b>

\* Includes Water Losses and Steam Cycle Makeup.  
Excludes GT Inlet Chilling.

## PAC SYSTEM®

### Typical Operating Characteristics



# 500 MW 2X1 CC w/ Dry Cooling





# ACC on 2X1 CC





## Typical Water Consumption at Full Load

Winter and summer shown to illustrate additional water consumption due to CT Evap Cooler operation

Demin Consumption with Evaps on	25.4 GPM
Service Water with Evaps on	<u>98.7 GPM</u>
Total Water Use	124.1 GPM
Avg Amb Temp with Evaps on	80.7 °F
Demin Consumption with Evaps Off	38.6 GPM
Service Water with Evaps Off	<u>8.7 GPM</u>
Total Water Use	47.3 GPM
Avg Amb Temp with Evaps Off	22.5 °F

## Typical Water Consumption Full Plant Start-up to a 2X1 Plant Configuration


Full plant start-up from no units running to both CT's on line and the Steam Turbine in normal operation. Approximate time for start-up in 10 hours.

Demin water consumption indicative of typical blowdown for chemistry control and for steam venting during ACC start-up.


	<u>Gallons Used</u>
<b>Demin Consumption through Start-UP</b>	<b>78,231</b>
<b>Service Water Consumption with Evaps on</b>	<b>51,422</b>
<b>Total Water Use</b>	<b>129,653</b>

# 500 MW 2X1 w/ Wet Cooling

- Cooling Tower Flow 166,166 GPM
- Cooling Tower Makeup Rate at full load 2,330 GPM
- Heat Rate 6,750 BTU/KWH HHV vs. 7,200 BTU/KWH HHV for a CC w/ Dry Cooling
- Aux. Load 10.5MW vs. 16.1MW (plant with ACC)
- Condenser Pressure 1.7 inches Hg vs. 3.5 (plant with ACC) – Dry Bulb 80F Wet Bulb 62F




# Ambient vs. Backpressure






# Ambient vs. Output




# Ambient vs. Heat Rate



## COM3 Site Looking East



# Comanche Station Looking Southeast





# Comanche Station Looking North



# Comanche Station Looking South





# Comanche Station Looking East



# Comanche Station Looking North





## Air Cooled Condenser (Dry Cooling)





# Air Cooled Condenser

03-20-2009



## Installation of Circulating Water Pipe





# Boiler Foundation

11-03-2006



Questions ?