



**Howden**

# Howden Netherlands

**A closer look to air side condenser performance**

Martin Huis in 't Veld

Date: 16 October 2013


# Air side condenser performance

## Site assessment






# Air side condenser performance

Site assessment: Volume, pressure, temperature – system resistance curve




Top view of ACC with measured fans.





# Air side condenser performance

## Increased air side performance



# Air side condenser performance

## Condensing data relation to fan air supply



# Air side condenser performance

## Process data estimation

ACC Input Values

Fill the columns, pay attention to the units and insert the values from suggested interval  
For successful calculation !!! ALL FIELDS MUST BE FILLED !!!

Media Input		Tube Features	
Volume flow per fan	464.8 m <sup>3</sup> /s	Tube length	9.532 m
Air inlet temperature	7.9 °C	Tube thickness	0.0015 m
Relative humidity	25.5 %	Material conductivity	50 W/mK
Ambient pressure	.884 bar a	Tube section shape:	<input checked="" type="radio"/> Oval/Oblong
Steam mass flow	367 kg/s		<input type="radio"/> Ellipic
Steam outlet enthalpy	2527 kJ/kg		<input type="radio"/> Round

ACC Body Construction		Fin Features	
Slope angle of tubes	30 deg	A-outer dimension	0.2195 m
Number of modules	56 -	B-outer dimension	0.0195 m
Number of bundles	10 -	Note: "A" is a longer dimension and "B" is shorter one; insert full axis length	
Number of tube rows	1 -		
Number of tubes per row	42 -		
Transversal pitch	0.057 m		
Longitudinal pitch	0.2 m		
Draft mode	<input checked="" type="radio"/> Forced		
	<input type="radio"/> Induced		
Note: Longitudinal represents length of fin in case of one row bundle			

**Insert Filled Values**

Note: Remember that fin has two sides

# Air side condenser performance

## Process data estimation



Stand\_alone\_version\_V2-datong - Microsoft Excel

Home Insert Page Layout Formulas Data Review View Developer

Clipboard Font Alignment Number Styles Cells Editing

Cells legend

- do not touch
- change by hand
- important cells
- must be equal

Calculation

tube inner circumference	L ti	m	0.461
tube outer circumference	L to	m	0.452
tube inner section	A ti	m <sup>2</sup>	0.004
tube outer section	A to	m <sup>2</sup>	0.004
tube inner characteristic dimension	d ri	m	0.030
tube outer characteristic dimension	d ro	m	0.041
Fin characteristic dimension	d f	m	0.080
minimum free flow area per fin pitch	A afp	m <sup>2</sup>	7.688E-05
partial water vapor pressure	p v	Pa	1029.8842
water in air	w	kg/kg	0.0018046
dry air density	p ai	kg/m <sup>3</sup>	1.1050369
wet air density	p awi	kg/m <sup>3</sup>	1.1038284
dry air inlet specific heat capacity	c pai	J/kgK	1006.4341
wet air specific heat capacity	c pawi	J/kgK	1007.9878
water vapor inlet specific heat capacity	c pwi	J/kgK	1868.9275
dry air dynamic viscosity	μ ai	Pa s	1.756E-05
wet air dynamic viscosity	μ awi	Pa s	1.755E-05
water vapor inlet dynamic viscosity	μ vi	Pa s	9.453E-06
dry air dynamic conductivity	k ai	W/mK	0.0247022
wet air dynamic conductivity	k awi	W/mK	0.0246844
water vapor inlet dynamic conductivity	k vi	W/mK	0.0175107
air mass flow	m a	kg/s	37812.203
wet inlet air Prandtl	Pr ai	-	0.7164969
mass velocity of air	G ai	kg/m <sup>2</sup> s	4.4153119
wet air inlet Reynolds	Re 1	-	10268.498
formula 5.5.1 Brigs+Young	h a1	W/m <sup>2</sup> K	31.651719
formula 49 Schmidt	h a2	W/m <sup>2</sup> K	28.139151
formula 50 VDI Heat atlas	h a3	W/m <sup>2</sup> K	34.858647
critical speed in the narrowest place	vc	m/s	3.9999983
vc-row effect coefficient	h nr	-	0.7982597
forced draft mode factor	h/h6	-	1.15
induced draft mode factor	h/h6	-	0.7
HTC air overall average	h ae	W/m <sup>2</sup> K	28.962711
air exposed area of condenser	A a	m <sup>2</sup>	1774187
nib area	A f	m <sup>2</sup>	1671001
tube inner area	A i	m <sup>2</sup>	118184.38
corresponding air mass flow over one half	m at	kg/s	0.703352
condensate enthalpy	i c	kJ/kg	169.16279
condensate density	ρ c	kg/m <sup>3</sup>	992.18651
condensate thermal conductivity	k c	W/mK	0.6315699
condensate dynamic viscosity	μ c	Pa s	0.0006466
HTC on condensate side	h c	W/m <sup>2</sup> K	12331.691
ribbing efficiency	Ω	-	0.8961223

Input table

V f [m <sup>3</sup> /s]	200	225	250	275	300
m s [kg/s]	210	210	210	210	210
t c [°C]	60.65	56.87	53.80	51.24	49.00
p c [kPa A]	20.55	17.23	14.87	13.13	11.80
Δp S [Pa]	23.79	26.96	30.19	33.45	36.70
E f [MW]	0.433	0.552	0.686	0.836	1.000

tc=f(Vf)

pc=f(Vf)

Start

Input table overview

Media Input

ACC Body Construction

Tube Features

Fin Features

Fan

Forced/Induced Draft

Fan overall efficiency

Turbine

Power output from turbine

Functions Calculation List of signs

Ready

CS 14:54 22-5-2013

# Air side condenser performance

## Process data



			Measurement
Nom. air flow per fan	$Q_{\text{air}}$	$\text{m}^3/\text{s}$	465
Nom. fan static pressure	$p_{\text{Static}}$	Pa	106
Fan shaft power	$P_{\text{Fan}}$	kW	82
Generated output	$E_{\text{turb}}$	MW	293
Steam mass flow per unit	$\dot{m}_{\text{steam}}$	kg/s	367.0
Condensing temperature	$t_{\text{C}}$	$^{\circ}\text{C}$	49.9
Condensing pressure	$t_{\text{p}}$	bar a	0.123
Condensate enthalpy	$h_{\text{C}}$	kJ/kg	207.5
Turbine inlet enthalpy	$h_{\text{turb}}$	kJ/kg	3395
Required fuel energy	$E_{\text{fuel}}$	MJ/s	1170.0

$$E_{\text{fuel}} = (h_{\text{turb}} - h_{\text{C}}) \times \dot{m}_{\text{steam}}$$



# Air side condenser performance

## Process data



			Measurement
Nominal air flow per fan	$Q_{\text{air}}$	ACFMx10 <sup>3</sup>	985
Nominal fan static pressure	$p_{\text{Static}}$	In H2O	0.426
Fan shaft power	$P_{\text{Fan}}$	HP	112
Generated output	$E_{\text{turb}}$	MW	
Steam mass flow per unit	$\dot{m}_{\text{steam}}$	lb/s	809.2
Condensing temperature	$t_c$	° F	121.8
Condensing pressure	$t_p$	PSI	1.784
Condensate enthalpy	$h_c$	btu/lb	89.3
Turbine inlet enthalpy	$h_{\text{turb}}$	btu/lb	1461
Required fuel energy	$E_{\text{fuel}}$	btu/s	1109645

$$E_{\text{fuel}} = (h_{\text{turb}} - h_c) \times \dot{m}_{\text{steam}}$$

# Air side condenser performance

## Estimated savings



			Measurement	+10%	
Nom. air flow per fan	$Q_{air}$	$m^3/s$	465	510	
Nom. fan static pressure	$p_{Static}$	Pa	106	128	
Fan shaft power	$P_{Fan}$	kW	82	108	
Generated output	$E_{turb}$	MW	293	293	
Steam mass flow per unit	$\dot{m}_{steam}$	kg/s	367.0	364.2	
Condensing temperature	$t_c$	$^{\circ} C$	49.9	47	
Condensing pressure	$t_p$	bar a	0.123	0.103	
Condensate enthalpy	$h_c$	kJ/kg	207.5	195.6	
Turbine inlet enthalpy	$h_{turb}$	kJ/kg	3395	3395	
Required fuel energy	$E_{fuel}$	MJ/s	1170.0	1165.2	$E_{fuel} = (h_{turb} - h_c) \times \dot{m}_{steam}$
Saving	$\Delta E_{fuel}$	MJ/day		407331	
Heat density coal		MJ/kg	25		$\Delta CO_2 = 3.667 \times \Delta Coal_{Cons} \times C_{coal}$
Coal saving per day	$\Delta Coal_{Cons}$	ton/day		16.3	
Estimated carbon content		%	70		$3.667 = \frac{44 \text{ kg [1kgmol } CO_2]}{12 \text{ kg [1kgmol C]}}$
CO2 saving per day	$\Delta CO_2$	ton/day		41.8	

# Air side condenser performance

## Estimated savings



			Measurement	+10%
Nominal air flow per fan	$Q_{air}$	ACFMx1 $0^3$	985	1081
Nominal fan static pressure	$p_{Static}$	In H2O	0.426	0.512
Fan shaft power	$P_{Fan}$	HP	112	147
Generated output	$E_{turb}$	MW		
Steam mass flow per unit	$\dot{m}_{steam}$	lb/s	809.2	802.9
Condensing temperature	$t_c$	° F	121.8	116.6
Condensing pressure	$t_p$	PSI	1.784	1.494
Condensate enthalpy	$h_c$	btu/lb	89.3	84.1
Turbine inlet enthalpy	$h_{turb}$	btu/lb	1461	1461
Required fuel energy	$E_{fuel}$	btu/s	1109645	1105173
Fuel saving per day	$\Delta E_{fuel}$	btu		386333458
Heat density coal		btu/lb	10755	
Coal saving per day	$\Delta Coal_{Cons}$	lb		35921
Estimated carbon content	$C_{coal}$	%	70	
CO2 saving per day	$\Delta CO_2$	lb		92198

$$E_{fuel} = (h_{turb} - h_c) \times \dot{m}_{steam}$$

$$\Delta CO_2 = 3.667 \times \Delta Coal_{Cons} \times C_{coal}$$

$$3.667 = \frac{44 \text{ kg [1kgmol CO}_2\text{]}}{12 \text{ kg [1kgmol C]}}$$

# Air side condenser performance

## Estimated savings



			Measurement	+10%	+15%	+20%
Nom. air flow per fan	$Q_{\text{air}}$	$\text{m}^3/\text{s}$	465	510	535	560
Nom. fan static pressure	$p_{\text{Static}}$	Pa	106	128	140	154
Fan shaft power	$P_{\text{Fan}}$	kW	82	108	125	143
Generated output	$E_{\text{turb}}$	MW	293	293	293	293
Steam mass flow per unit	$\dot{m}_{\text{steam}}$	kg/s	367.0	364.2	362.7	361.9
Condensing temperature	$t_c$	$^{\circ}\text{C}$	49.9	47	45.7	44.8
Condensing pressure	$t_p$	bar a	0.123	0.103	0.100	0.0949
Condensate enthalpy	$h_c$	kJ/kg	207.5	195.6	189.9	186.3
Turbine inlet enthalpy	$h_{\text{turb}}$	kJ/kg	3395	3395	3395	3395
Required fuel energy	$E_{\text{fuel}}$	MJ/s	1170.0	1165.2	1162.5	1161.2
Saving	$\Delta E_{\text{fuel}}$	MJ/day		407331	644924	753895
Heat density coal		MJ/kg	25			
Coal saving per day	$\Delta \text{Coal}_{\text{Cons}}$	ton/day		16.3	25.8	30.2
Estimated carbon content		%	70			
CO2 saving per day	$\Delta \text{CO}_2$	ton/day		41.8	66.2	77.4

# Air side condenser performance


## Estimated savings



			Measurement	+10%	+15%	+20%
Nominal air flow per fan	$Q_{air}$	ACFMx10 <sub>3</sub>	985	1081	1134	1187
Nominal fan static pressure	$p_{Static}$	In H2O	0.426	0.512	0.563	0.617
Fan shaft power	$P_{Fan}$	HP	112	147	170	195
Generated output	$E_{turb}$	MW				
Steam mass flow per unit	$\dot{m}_{steam}$	lb/s	809.2	802.9	799.6	797.9
Condensing temperature	$t_C$	° F	121.8	116.6	114.3	112.6
Condensing pressure	$t_p$	PSI	1.784	1.494	1.450	1.376
Condensate enthalpy	$h_c$	btu/lb	89.3	84.1	81.7	80.1
Turbine inlet enthalpy	$h_{turb}$	btu/lb	1461	1461	1461	1461
Required fuel energy	$E_{fuel}$	btu/s	1109645	1105173	1102565	1101369
Fuel saving per day	$\Delta E_{fuel}$	btu		386333458	611678959	715032787
Heat density coal		btu/lb	10755			
Coal saving per day	$\Delta Coal_{Cons}$	lb		35921	56874	66484
Estimated carbon content	$C_{coal}$	%	70			
CO2 saving per day	$\Delta CO_2$	lb		92198	145976	170642

# Air side condenser performance


## Costs versus incentives



# Air side condenser performance

## Increased air supply – Blade angle

[Pa]




- Increased power consumption to compensate reduced efficiency.
- Increased risk of stall due to reduced pressure margin.

Air flow	$\Delta$ PWL
%	db(A)
120	2.4
115	1.8
110	1.2
105	0.6
100	0.0
95	-0.7
90	-1.4
85	-2.1

# Air side condenser performance

Increased air supply – More speed



Volume: 
$$\frac{Q_2}{Q_1} = \frac{n_2}{n_1}$$

Pressure: 
$$\frac{p_2}{p_1} = \left(\frac{n_2}{n_1}\right)^2$$

Abs. Power: 
$$\frac{P_{Fan2}}{P_{Fan1}} = \left(\frac{n_2}{n_1}\right)^3$$









Noise: 
$$\Delta PWL = 60 \text{LOG} \left(\frac{n_2}{n_1}\right)$$



# Air side condenser performance

Increased air supply – More speed

Basic formula:  $PWL_{Fan} = C + 30LOGU_{Tip} + 10LOGP_{Aero} - 5LOGD_{Waaier} + \Delta dB$

	ENF / DNF	ELF / DLF	ELFA / DVF	SX / FPX
Shape				
Noise Classification	 Standard	 Low-noise	 Very low-noise	 Ultra low-noise

Air flow	$\Delta$ PWL
%	
120	4.8
115	3.6
110	2.5
105	1.3
100	0.0
95	-1.3
90	-2.7
85	-4.2

# Air side condenser performance

## Retrofit – Extrapolating a new fan duty

Output kW	Motor type	Product code	Speed r/min	Efficiency		Power
				Full load 100%	3/4 load 75%	factor cos φ 100%

1000 r/min = 6-poles

75	M3BP	315 SMA	3GBP	313 21
90	M3BP	315 SMB	3GBP	313 22
110	M3BP	315 SMC	3GBP	313 23
132	M3BP	315 MLA	3GBP	313 41



Output kW	Motor type	Product code	Speed r/min	Efficiency Full load	Efficiency 3/4 load	Power factor cos φ
1500 r/min = 4-poles						
110	M3BP	315 SMA	3GBP	312 210-••G	1487	95.6 95.4 0.86
132	M3BP	315 SMB	3GBP	312 220-••G	1487	95.8 95.7 0.86
160	M3BP	315 SMC	3GBP	312 230-••G	1487	96.0 95.9 0.85
200	M3BP	315 MLA	3GBP	312 410-••G	1486	96.2 96.2 0.86


400 V 50 Hz

# Air side condenser performance

Retrofit – Extrapolating a new fan duty



$$P = \frac{T \times n}{9550}$$



Costs vary. Major question marks are:

- Noise requirements?
- Power supply / Cabling capacity?

# Air side condenser performance

## Coal saving



			Measurement	+10%	+15%	+20%
Nominal air flow per fan	$Q_{air}$	$m^3/s$	465	510	535	560
Required fuel energy	$E_{fuel}$	MJ/s	1170.0	1165.2	1162.5	1161.2
Saving	$\Delta E_{fuel}$	MJ/day		407331	644924	753895
Heat density coal		MJ/kg	25			
Coal saving	$\Delta Coal_{Cons}$	ton/day		16.3	25.8	30.2
Price black coal / ton		RMB	450			
		USD	74			
Saving in black coal/year		RMB		2,676,163	4,237,150	4,953,090
		USD		438,715	694,615	811,982



# Air side condenser performance

## CO<sub>2</sub> saving




			Measurement	+10%	+15%	+20%
Nominal air flow per fan	$Q_{\text{air}}$	m <sup>3</sup> /s	465	510	535	560
Coal saving per day	$\Delta\text{Coal}_{\text{Cons}}$	ton		16.3	25.8	30.2
Estimated carbon content	$C_{\text{coal}}$	%	70			
CO <sub>2</sub> saving per day	$\Delta\text{CO}_2$	ton/day		41.8	66.2	77.4
Costs CO <sub>2</sub> emission per ton		RMB	30			
		USD	5			
Saving in CO <sub>2</sub> emission		RMB		457,921	725,023	847,529
		USD		75,069	118,856	138,939

# Air side condenser performance

## Costs versus incentives

	<b>+10%</b>	<b>+15%</b>	<b>+20%</b>
Total savings/year			
RMB	3,134,085	4,962,173	5,800,619
USD	513,784	813,471	950,921



Major question marks are:

- Noise requirements.
- Power supply / Cabling capacity



Howden

# Howden Netherlands

**Do take** a closer look to air side condenser performance!

Martin Huis in 't Veld

Date: 16 October 2013