




Howden Netherlands

A closer look to air side condenser performance

Air side condenser performance

Cooling capacity in relation to plant output


more cooling capacity = more plant output



Air side condenser performance

Cooling capacity in relation to cost reduction

more cooling capacity = more process efficiency = cost reduction




Air side condenser performance

Site assessment






Air side condenser performance

Site assessment: Volume, Pressure, Temperature – System resistance curve




Top view of ACC with measured fans.




Air side condenser performance

Increased air side performance



Air side condenser performance

Condensing data in relation to fan air supply



Air side condenser performance

Process data estimation



ACC Input Values

Fill the columns, pay attention to the units and insert the values from suggested interval
For successful calculation !!! ALL FIELDS MUST BE FILLED !!!

Media Input

Volume flow per fan	464.8	m ³ /s
Air inlet temperature	7.9	°C
Relative humidity	25.5	%
Ambient pressure	.884	bar a
Steam mass flow	367	kg/s
Steam outlet enthalpy	2527	kJ/kg

Tube Features

Tube length	9.532	m
Tube thickness	0.0015	m
Material conductivity	50	W/mK
Tube section shape:	<input checked="" type="radio"/> Oval/Oblong	
	<input type="radio"/> Ellipic	
	<input type="radio"/> Round	
A-outer dimension	0.2195	m
B-outer dimension	0.0195	m

Note: "A" is a longer dimension and "B" is shorter one; insert full axis lenght

ACC Body Construction

Slope angle of tubes	30	deg
Number of modules	56	-
Number of bundles	10	-
Number of tube rows	1	-
Number of tubes per row	42	-
Transversal pitch	0.057	m
Longitudinal pitch	0.2	m
Draft mode	<input checked="" type="radio"/> Forced	
	<input type="radio"/> Induced	

Note: Longitudinal represents lenght of fin in case of one row bundle

Fin Features

Fin pitch	0.0023	m
Fin thickness	0.00025	m
Material conductivity	250	W/mK
Fin spacing	<input checked="" type="radio"/> No spacing	
	<input type="radio"/> Gaps between	

Note: Remember that fin has two sides

Insert Filled Values

Air side condenser performance

Process data estimation

Stand_alone_version_V2-datong - Microsoft Excel

Cells legend

- do not touch
- change by hand
- important cells
- must be equal

Input table overview

Media Input

8 volume flow per fan	V f	m ³ /s	538,2
9 air inlet temperature	t ai	°C	7,4
10 relative humidity	φ	-	25,0
11 ambient pressure	p b	bar a	0,890
12 steam mass flow	m s	kg/s	367.000
13 steam outlet enthalpy	i s1	kJ/kg	2527,0
14 expected condensation temperature	t c	°C	40,388
15			
16 ACC Body Construction			
17 half of top point angle	θ	deg	30
18 modules	n m	-	64
19 bundles per module	n b	-	10
20 number of rows	n r	-	1
21 tubes per row in bundle	n t	-	42
22 transversal pitch	P t	m	0,057
23 longitudinal pitch	P l	m	0,200
24			0,000
25 Tube Features			
26 tube length	l t	m	9,5
27 tube thickness	t t	m	0,002
28 tube thermal conductivity	k t	W/mK	50,0
29 A-outer characteristic dimension	a t	m	0,220
30 B-outer characteristic dimension	b t	m	0,020
31			
32 Fin Features			
33 Fin pitch	P f	m	0,00230
34 Fin thickness	t f	m	0,0003
35 Fin thermal conductivity	k f	W/mK	250.000
36 Fin area per fin pitch(without t f)	A fp	m ²	0,015
37 Fin circumference	L fp	m	0,875
38			
39 Fan			
40 Forced/Induced Draft	D	-	1
41 Fan overall efficiency	η f	%	55
42			
43 Turbine			
44 Power output from turbine	E t	MW	290.000


Calculation

tube inner circumference	L ti	m	0,461
tube outer circumference	L to	m	0,452
tube inner section	A ti	m ²	0,004
tube outer section	A to	m ²	0,004
tube inner characteristic dimmension	d ri	m	0,030
tube outer characteristic dimmension	d ro	m	0,041
Fin characteristic dimension	d f	m	0,080
minimum free flow area per fin pitch	A afp	m ²	7,688E-05
partial water vapor pressure	p v"	Pa	1029,8842
water in air	w	kg/kg	0,0018046
dry air density	p ai	kg/m ³	1,1050369
wet air density	p awi	kg/m ³	1,1038284
dry air inlet specific heat capacity	c pai	J/kgK	1006,4341
wet air specific heat capacity	c pawi	J/kgK	1007,9878
water vapor inlet specific heat capacity	c pvi	J/kgK	1868,9275
dry air dynamic viscosity	μ ai	Pa s	1,756E-05
wet air dynamic viscosity	μ awi	Pa s	1,755E-05
water vapor inlet dynamic viscosity	μ vi	Pa s	9,453E-06
dry air dynamic conductivity	k ai	W/mK	0,0247022
wet air dynamic conductivity	k awi	W/mK	0,0246844
water vapor inlet dynamic conductivity	k vi	W/mK	0,0175107
air mass flow	m a	kg/s	37812,203
wet inlet air Prandtl	Pr ai	-	0,7164969
mass velocity of air	G ai	kg/m ² s	4,4153119
wet air inlet Reynolds	Re 1	-	10268,498
formula 5.5.1 Briggs+Young	h a1	W/m ² K	31,651719
formula 49 Schmidt	h a2	W/m ² K	28,139151
formula 50 VDI Heat atlas	h a3	W/m ² K	34,858647
critical speed in the narrowest place	v c	m/s	3,9999983
vc+row effect coefficient	h nr	-	0,7982597
forced draft mode factor	h/h6	-	1,15
induced draft mode factor	h/h6	-	0,7
HTC air overall average	h ae	W/m ² K	28,962711
air exposed area of condenser	A a	m ²	1774187
rib area	A f	m ²	1671001
tube inner area	A i	m ²	118184,38
corresponding air mass flow over one hal	m at	kg/s	0,703352
condensate enthalpy	i c	kJ/kg	169,16279
condensate density	p c	kg/m ³	992,18651
condensate thermal conductivity	k c	W/mK	0,6315699
condensate dynamic viscosity	μ c	Pa s	0,0006466
HTC on condensate side	h c	W/m ² K	12331,691
ribbing efficiency	Ω	-	0,8961223

Input table


	1	2	3	4	5
V f [m ³ /s]	200	225	250	275	300
m s [kg/s]	210	210	210	210	210
t c [°C]	60,65	56,87	53,80	51,24	49,0
p c [kPa A]	20,55	17,23	14,87	13,13	11,8
Δp S [Pa]	23,79	26,96	30,19	33,45	36,7
E f [MW]	0,433	0,552	0,686	0,836	1,0

tc=f(Vf)



Vf [m ³ /s]	tc [°C]
200	60,65
225	56,87
250	53,80
275	51,24
300	49,0

pc=f(Vf)



Vf [m ³ /s]	pc [kPa A]
200	20,55
225	17,23
250	14,87
275	13,13
300	11,8

Air side condenser performance

Process data



Measurement			
Nom. air flow per fan	Q_{air}	m^3/s	465
Nom. fan static pressure	p_{static}	Pa	106
Fan shaft power	P_{Fan}	kW	82
Generated output	E_{turb}	MW	293
Steam mass flow per unit	\dot{m}_{steam}	kg/s	367
Condensing temperature	t_C	$^{\circ}C$	49,9
Condensing pressure	t_p	bar a	0,123
Condensate enthalpy	h_c	kJ/kg	207,5
Turbine inlet enthalpy	h_{turb}	kJ/kg	3395
Required fuel energy	E_{fuel}	MJ/s	1170
			$E_{fuel} = (h_{turb} - h_c) \times \dot{m}_{steam}$

Air side condenser performance

Estimated savings when increasing airflow



			Measurement	+10%
Nom. air flow per fan	Q _{air}	m ³ /s	465	→ 510
Nom. fan static pressure	p _{Static}	Pa	106	128
Fan shaft power	P _{Fan}	kW	82	108
Generated output	E _{turb}	MW	293	293
Steam mass flow per unit	ṁ _{steam}	kg/s	367	364,2
Condensing temperature	t _c	°C	49,9	47
Condensing pressure	t _p	bar a	0,123	0,103
Condensate enthalpy	h _c	kJ/kg	207,5	195,6
Turbine inlet enthalpy	h _{turb}	kJ/kg	3395	3395
Required fuel energy	E _{fuel}	MJ/s	1170	1165,2 E _{fuel} = (h _{turb} - h _c) x ḡ _{steam}
Saving	ΔE _{fuel}	MJ/day		407331
Heat density coal		MJ/kg	25	
Coal saving per day	ΔCoal _{Cons}	ton/day		16,3 3,667 = $\frac{44 \text{ kg [1kgmol CO}_2\text{]}}{12 \text{ kg [1kgmol C]}}$
Estimated carbon content	C _{coal}	%	70	
CO ₂ saving per day	ΔCO ₂	ton/day		41,8 ΔCO ₂ = 3,667 x ΔCoal _{Cons} x C _{coal}

Air side condenser performance

Estimated savings when increasing airflow



			Measurement	+10%	+15%	+20%
Nom. air flow per fan	Q_{air}	m^3/s	465	510	535	560
Nom. fan static pressure	p_{static}	Pa	106	128	140	154
Fan shaft power	P_{Fan}	kW	82	108	125	143
Generated output	E_{turb}	MW	293	293	293	293
Steam mass flow per unit	\dot{m}_{steam}	kg/s	367.0	364.2	362.7	361.9
Condensing temperature	t_c	°C	49.9	47	45.7	44.8
Condensing pressure	t_p	bar a	0.123	0.103	0.100	0.0949
Condensate enthalpy	h_c	kJ/kg	207.5	195.6	189.9	186.3
Turbine inlet enthalpy	h_{turb}	kJ/kg	3395	3395	3395	3395
Required fuel energy	E_{fuel}	MJ/s	1170.0	1165.2	1162.5	1161.2
Saving	ΔE_{fuel}	MJ/day		407331	644924	753895
Heat density coal		MJ/kg	25			
Coal saving per day	$\Delta Coal_{Cons}$	ton/day		16.3 → 25.8	→ 30.2	
Estimated carbon content		%	70			
CO2 saving per day	ΔCO_2	ton/day		41.8 → 66.2	→ 77.4	

Air side condenser performance

Estimated savings when increasing airflow



			Measurement	+10%	+15%	+20%
Nominal air flow per fan	Q_{air}	m^3/s	465	510	535	560
Required fuel energy	E_{fuel}	MJ/s	1170	1165,2	1162,5	1161,2
Saving	ΔE_{fuel}	MJ/day		407331	644924	753895
Heat density coal		MJ/kg	25			
Coal saving	$\Delta Coal_{Cons}$	ton/day		16,3	25,8	30,2
Price black coal / ton		RMB	400			
Saving in black coal/year		RMB		2.380.000	3.770.000	4.410.000
		Euro		332.000	526.000	616.000



Air side condenser performance


Estimated savings when increasing airflow



			Measurement	+10%	+15%	+20%
Nominal air flow per fan	Q_{air}	m^3/s	465	510	535	560
Coal saving per day	$\Delta Coal_{cons}$	ton		16,3	25,8	30,2
Estimated carbon content	C_{coal}	%	70			
CO2 saving per day	ΔCO_2	ton/day		41,8	66,2	77,4
Costs CO2 emission per ton		RMB	25			
Saving in CO2 emission/year		RMB		382.000	604.000	706.000
		Euro		53.000	85.000	99.000
Total savings/year		RMB	+10%	+15%	+20%	
		Euro	2.762.000	4.374.000	5.116.000	715.000

Air side condenser performance

Increased air supply – Blade angle




- Increased power consumption to compensate reduced efficiency.
- Increased risk of stall due to reduced pressure margin.

Air flow %	$\Delta \text{PWL db(A)}$
120	2.4
115	1.8
110	1.2
105	0.6
100	0.0
95	-0.7
90	-1.4
85	-2.1

Air side condenser performance

Increased air supply – Higher fan speed



Air flow volume:

$$\frac{Q_2}{Q_1} = \frac{n_2}{n_1}$$

Fan static pressure:

$$\frac{p_2}{p_1} = \left(\frac{n_2}{n_1} \right)^2$$

Absorbed power:

$$\frac{P_{Fan2}}{P_{Fan1}} = \left(\frac{n_2}{n_1} \right)^3$$





Noise:

$$\Delta PWL = 60 \log \left(\frac{n_2}{n_1} \right)$$

Air side condenser performance

Increased air supply – Noise level

Basic formula: $PWL_{Fan} = C + 30LOGU_{Tip} + 10LOGP_{Aero} - 5LOGD_{Waaier} + \Delta dB$

	ENF / DNF	ELF / DLF	ELFA / DVF	SX / FPX
Shape				
Noise Classification	 Standard	 Low-noise	 Very low-noise	 Ultra low-noise

Air side condenser performance


Retrofit – Extrapolating a new fan duty



Output kW	Motor type	Product code	Speed r/min	Efficiency		Power factor $\cos \phi$
				Full load 100%	3/4 load 75%	

1000 r/min = 6-poles

75	M3BP	315 SMA	3GBP	313 21
90	M3BP	315 SMB	3GBP	313 22
110	M3BP	315 SMC	3GBP	313 23
132	M3BP	315 MLA	3GBP	313 41



Output kW	Motor type	Product code
--------------	------------	--------------

1500 r/min = 4-poles

400 V 50 Hz

110	M3BP	315 SMA	3GBP	312 210-•G	1487	95.6	95.4	0.86
132	M3BP	315 SMB	3GBP	312 220-•G	1487	95.8	95.7	0.86
160	M3BP	315 SMC	3GBP	312 230-•G	1487	96.0	95.9	0.85
200 ²⁾	M3BP	315 MLA	3GBP	312 410-•G	1486	96.2	96.2	0.86

Air side condenser performance


Retrofit – Extrapolating a new fan duty



$$P = \frac{T \times n}{9550}$$

Air side condenser performance

Return On Investment



f.e. 20% improvement:

56 x 30ELF fans	RMB 6.500.000
56 x 160kW E-Motor	RMB 2.800.000
<u>Installation costs</u>	RMB 3.000.000
Total costs	RMB 12.300.000

Savings per year:

RMB 5.116.000 (Pay back time ≈ 2,5 years)

Site assessment:

- knowledge of the actual air side performance
- reliable prediction of the improvement

Why increase air side performance?

- more plant output against same fuel consumption and CO2 emission
- same plant output, but less fuel consumption and CO2 emission

How increase air side performance?

- Blade angle
- Increase fan speed
- Increase motor power
- Replace fan
- and many combinations

Benefits

- Relative low investment
- Short pay back time
- Not only “end of life time replacement” but PROCESS IMPROVEMENT



Ewald Stegeman
Sales Engineer Retrofit



E-mail : ewald.stegeman@howden.com
Mobile : +31 651626229
Office : +31 742556035
Website : www.howden.com

Time for questions

Revolving Around You