



# Medupi Power Station ACC Performance During Windy Conditions

2017 ACCUG Las Vegas

3 October 2017

Presented by **Ockert Augustyn**

- ACC specification
  - Performance specification
  - Minimum design features
- Medupi ACC specification
- Matimba and Medupi Design
- ACC Performance

- Eskom – only power utility in South Africa
- 4 ACCs
  - Majuba > 3 x 657 MW [1996-2001]
  - Matimba > 6 x 665 MW [1987-1991]
  - Medupi > 6 x 794 MW [3 units operational]
  - Kusile > 6 x 800 MW [1 unit operational]
- Fans: 48-64 (~10m diameter) per unit
- Platform height: 45-60m

# Eskom ACC fleet



## Performance specification

- ACC performance requirements are specified by purchaser
- Supplier is responsible for all design aspects of the ACC
- Performance guarantees are verified by acceptance test
- Suitable specification/tolerance for performance drop during adverse weather
- Low risk to supplier since test codes limit wind speed during test

*>> Performance parameters used to mitigate risks*

## Significant risks for purchaser associated with performance specification

- Supplier may assume that safety margins or features added to their bid would render them less competitive
- Purchaser may not be able to disqualify offers or justify more expensive offers
  - *All offers may claim to meet performance requirements*

## Significant risks for purchaser associated with performance specification

- Performance characteristics of an ACC in windy conditions remain unknown until commissioning
  - Usually too late to implement design changes if required
- Successful test provide no guarantee that performance will not degrade significantly under high wind speeds

- **ACC specification type**
  - Performance specification
- **Operational experience**
  - Significant capacity loss during adverse weather (high temperature, wind speed & direction)
  - 12 vacuum related units trips occurred at Matimba during first 7 years of operation
  - 2016 – multiple cases of >1000MW load loss



- Performance test was successful
  - Test done during favourable wind direction

>> **Conclusion:** Performance specification is not acceptable due to high performance risk



## **Purchaser specifies minimum ACC design features**

> mitigate performance deterioration during adverse conditions

## **Advantage to Purchaser**

- All offers must comply with minimum requirements
- No surprises during tendering process
- ACC position is fixed at early stage
- Mitigation for wind effect is incorporated in design

## Purchaser specifies minimum ACC design features

### Advantage to Supplier

- All suppliers tender on same basis
- Minimum design features are defined

>> Require purchaser to perform basic analysis in advance (informed client)

- Atmospheric conditions based on 40 m Above Ground Level
- Design Wind speed 9 m/s from any direction
- Wind wall height to extend to top of steam duct
- 2.5 m wide solid walkway around entire perimeter of platform
- Wind cross on ground level, 33% of fan inlet height
- Performance guarantees had to be verified by means of CFD analysis before construction

# Requirements for the Medupi ACC

- 50 m Gap between ACC and Turbine House





# Requirements for the Medupi ACC

- No gap shown for Matimba



# Medupi ACC – wind wall



# Medupi ACC





# ACC design comparison


|                                      | <b>Matimba</b> | <b>Medupi</b> |
|--------------------------------------|----------------|---------------|
| Total Gross Electrical Output, MW    | 6 x 665        | 6 x 794       |
| Total heat rejection rate by ACC, MW | 6 x 905        | 6 x 932       |
| Design Ambient Temperature, °C       | 18             | 23.7          |
| Design Wind Speed, m/s               | 0              | 9             |
| Design ACC pressure, kPa(a)          | 17.9           | 14.1          |
| Total ACC platform length, m         | 509            | 669           |
| Platform Width, m                    | 70.8           | 108           |
| Fan inlet height, m                  | 45             | 54            |
| Wind wall height, m                  | 10             | 14.4          |
| Fan stall margin, %                  | 10             | 65            |
| Walkway width, m                     | 1.5            | 2.5           |
| Number of fans                       | 6 x 48         | 6 x 64        |
| Fan Diameter, ft.                    | 30             | 34            |

- Medupi unit 6 went into commercial operation in October 2015
- Official performance test done in December 2015
  - ACC performance measurably better than design
- **No** vacuum related load losses experienced since commissioning
- Due to close proximity of Medupi and Matimba the performances of the two ACC can be compared directly


# Proximity of Matimba



# Matimba vacuum related load losses



# Medupi 6 performance, 24 October 2016



- Success of design features clearly demonstrated by site measurements
- Relative low cost requirements renders ACC performance almost immune to wind effects
- All incorporated into the initial design



- Purchaser to specify minimum ACC design features to minimize wind effects
  - Upfront work is required
- CFD as part of design can be omitted
- Fan pressure margin at selected blade angle of around 60% to be specified
  - In addition a high fan solidity at mid-span to be specified ( $> 0.4$ )

- The significant contribution made by the late Prof. D.G. Kröger is gratefully acknowledged.
  - Many of the design features incorporated in the Medupi ACC follows directly from his tireless work.
- Dr. Francois du Preez, co-author and lead engineer at Eskom.





# Questions