




ACCUG: Corrosion and Cycle Chemistry

Fossil, Combined Cycle/HRSG and Industrial Plants
Review of History over Last 20 Years




Barry Dooley

ACCUG 2026
14th & 15th July 2026
Clarksville, Tennessee



1

ACC Come in Many Sizes



But the two-phase FAC at the tube entries is the same worldwide with all chemistries and plant types (Based on assessment/inspection work conducted in Australia, Canada, Chile, China, Cote d'Ivoire, Dubai, India, Ireland, Mexico, Qatar, Abu Dhabi, South Africa, Trinidad, UK and US)

2

Corrosion/FAC in ACC has Serious Consequences

- High concentrations of iron around the cycle
 - Boiler/HRSG deposits (expensive chemical cleaning)
 - Boiler/HRSG Tube Failures (overheating and UDC / HD*)
 - Steam Turbine Deposits (including aluminum)
- Need for Iron Removal Processes
 - Condensate Polishing and/or Filters (5 µm absolute preferred)
- Limitations around the cycle
 - Condensate polishing (may have to change mode to AFO*)
- Overall, an ACC "controls" the unit cycle chemistry
 - International Guidelines are freely available for ACC and two-phase flow (IAPWS Volatile and FFS Guidance)

IAPWS

* UDC / HD – Under-deposit corrosion / hydrogen damage.
* AFO – Ammonium form operation


3

A Wide Variety of ACC Corrosion on Inspection




Structural Integrity
Associates, Inc.

4



Discussion Items for ACCUG 2026



Reminder of ACC Damage & How it is Normally Addressed
DHACI provides uniformity for Inspections Worldwide
Monitoring Cycle Chemistry (total iron)
Introduction & Update of Film Forming Substances (FFS)
International Experiences & Missing Information



July 2026




5

There is an ACC Corrosion Index to Categorize Corrosion and Track Improvements

DHACI

(Dooley, Howell, Air-cooled Condenser,
Corrosion Index)



6

DHACI for Tube Entries

1. Tube entries in relatively good shape (maybe some dark deposited areas)
2. Various black/grey deposits on tube entries as well as flash rust areas, but no white bare metal areas
3. Few white bare metal areas on a number of tube entries. Some black areas of deposit
4. Serious white bare metal areas on/at numerous tube entries. Lots of black areas of deposition adjacent to white areas
5. Most serious. Holes in the tubing or welding. Obvious corrosion on many tube entries

Examples included on following slides

Dooley & Howell et al, PPChem 2009



7

DHACI for Steam Transport Ducts


- A. Ducting shows no general signs of two-phase damage
- B. Minor white areas on generally grey ducting. Maybe some tiger striping with darker grey/black areas of two-phase damage
- C. Serious white bare metal areas in the hot box and at numerous changes of direction (eg. at intersections of exhaust ducting to vertical riser). White areas are obvious regions of lost metal.

Overall, an ACC maybe described as 4B

Dooley & Howell et al, PPChem 2009



8



Air Cooled Condenser Users Group

<http://acc-usersgroup.org/>

ACC.01

Original Issue: May 12, 2015

Revision due: May 12, 2018

Guideline for Internal Inspection of Air-Cooled Condensers

9

Inspections Worldwide show the same Features


Combined Cycle with ACC after ~ 15,000 hrs, pH 9.1.



10


Inspections Worldwide show the same Features

750 MW Supercritical on OT at pH 9, ~4,000 hrs.



11

Damage takes time to Arrest (after 2 Years with pH 9.8)



12

Damage takes time to arrest (15 Months with pH 9.8)



13

Damage takes time to arrest (2 Years with pH 9.8)




Structural Integrity
Associates, Inc.

14

ACC Two-phase FAC can be "Arrested" with FFS

(Example of Significant Reduction in DHACI for FAC at Tube Entries in ACC. Accompanied by Significant Reduction of Total Iron in Condensate. But many cases where FFA and FFP have not "arrested" ACC FAC) (and word of caution about using FFS – see later)




For ACC the FAC / Corrosion damage is the same worldwide with all chemistries and plant types (Based on assessment / inspection work conducted in Australia, Canada, Chile, China, Cote d'Ivoire, Dubai, India, Ireland, Mexico, Qatar, Abu Dhabi, UAE, South Africa, Trinidad, UK and US)

SLIDE 15

15

To Understand the FAC/Corrosion here we need to Understand the Environment in the PTZ of the LP Turbine




Structural Integrity
Associates, Inc.

16

The PTZ Environment in the LP Steam Turbine is Completely Understood

Mollier Diagram
A. Fossil Reheat Turbine
B. Backpressure Turbine
C. Reheat Turbine in a nuclear LWR plant



Source: IAPWS Technical Guidance Document on Steam Purity

Structural Integrity Associates, Inc.


Generation of the ACC Environment

Heterogeneous droplet Nucleation and Liquid Films on ST Blades

(Droplets and Liquid Films in the ACC vary from 0.1 – 50 microns and don't contain any oxygen until during shutdown)

LAP WS


Generation of the ACC Environment is in the PTZ



Adapted from Dooley and Dooley and Rieger, 2001

Structural Integrity Associates, Inc.


The Liquid in ACC Upper Ducts (Lower pH and higher chlorides)



Validated and Courtesy:
 Setsweke Phala, Eskom

Structural Integrity Associates, Inc.

Inside diameter surface of an ACC Tube



Structural Integrity Associates, Inc.

Another Tube Showed the Same Features




6 inch section of ACC tube and detail of the surface showing black deposits and white "bare" metal areas. Note some Fe_2O_3 has turned red


Structural Integrity
Associates, Inc.

21


Corroded (FAC?) ID Surface of ACC Tube



Oxide free area with preferential grain boundary attack (white)



Black Deposited Oxide




Preferential grain boundary corrosion attack


Structural Integrity
Associates, Inc.

22

Typical Microscopic Appearance of FAC and ACC Corrosion



"Normal" FAC in Fossil Feedwater and in Combined Cycle/HRSG Circuits




"FAC" Damage in ACCs (white areas)

Structural Integrity
Associates, Inc.

23

Monitoring Condensate Iron to Categorize Corrosion and Track Improvements



Air Cooled Condenser Users Group

24



Sampling and Analysis of Corrosion Products

Something Old - IAPWS 2014 TGD • Something New – IAPWS 2025 White Paper

Suitable methods

- Sampling and locations
- Post sample digestion UV-Vis (Ferrozine) with a 5 cm cell - Fe only
- Graphite Furnace Atomic Absorption spectrometry (GF-AA) post sample digestion
- Inductively coupled plasma mass spectrometry (ICP-MS) post sample digestion

Key points are:

1. Full digestion for all samples required
2. Detection limit of $< 2 \mu\text{g/kg}$ required (lower the DL the better)

IAPWS TGD 6-13, September 2014

25



Achievable Total Fe (& Cu) Levels Different Plant Types/Optimized Chemistry Steady/Base Loaded Plants

Feedwater

OT:	Total Fe =	$< 1 \mu\text{g/kg}$
AVT:	Total Fe =	$< 2 \mu\text{g/kg}$
AVT (Mixed):	Total Fe & Cu =	$< 2 \mu\text{g/kg}$
HP/LP Heater Drains:	Total Fe & Cu =	$< 1 \mu\text{g/kg}$

HRSG Evaporators/Drums

AVT/PT/CT:	Total Fe =	$< 5 \mu\text{g/kg}$
------------	------------	----------------------

Units with Air-Cooled Condenser (ACC)

ACC Outlet:	Total Fe =	$< 10 \mu\text{g/kg}$
Post Condensate Filter:	Total Fe =	$< 5 \mu\text{g/kg}$

Cogeneration / Industrial Plants


Condensate Return:	Total Fe =	$< 10 \mu\text{g/kg}$
--------------------	------------	-----------------------

IAPWS TGD 6-13, September 2014

Higher than these values indicates an RCCS
(A cycle chemistry deficiency)

26

Plant Improvements in ACCs (reduction of total iron) are Directly in Agreement with the Dooley/Aspden relationship



Source: Richardson and Joy, Data from 650 MW Unit with ACC

Structural Integrity
Associates, Inc.


27

New IAPWS Procedure to Quantify CP Transport During Startup

For Fast Start or Frequently Started Plants the important Corrosion Product Indicator is how quickly the Fe decay takes place from the high shutdown level during startup. This can be monitored by using Proxy Analysis for Total Iron (turbidity) and overlaying the decay profile on IAPWS Decay Map

- Summary of procedure
 - Flush feedwater sample point as soon as pressure is available
 - Measure and register oxide levels in feedwater by proxy methods during startup
 - Take samples for filtered iron intermittently to establish correlation to proxy results
 - Note times for milestones: First fire, by-pass, turbine roll-up, synchronisation etc.
 - Plot iron levels versus time after First fire, mark milestones
 - Integrate (iron level * feedwater flow) from First fire to steady-state level → iron transported to boiler during startup

Example: Startup of a Well Operated HRSG Plant




101 GT fire
102 FWT heating
103 Make-up
104 ST sync
Iron transported: 4.3 g


Combined Cycle/HRSG.
AVT(O) feedwater. Dry
air preservation.

IAPWS White Paper, January 2025


28




29



30



31



32



Update on the use of an FFS

Film Forming Amines (FFA)

Octadecylamine – ODA

Oleyamine – OLA

Oleyl Propylenediamine – OLDA

Film Forming Products (FFP)

Proprietary

Please ensure you use Section 8 in the IAPWS Guidance: Corrosion Products and Internal WW and HP Evaporator Deposits

IAPWS TGD: Application of FFS in Fossil, Combined Cycle and Biomass Plants (October 2019). This document covers optimum application guidance for FFA / FFAP / FFP in all-ferrous plants. It also includes customizations for shutdown / layup, multiple pressures, mixed-metallurgy feedwater systems, condensate polishing, and units with ACC. [TGD8-16\(2019\)](#)


Application of FFS in Industrial Steam Generators (October 2019). This document covers optimum application guidance for FFA / FFAP / FFP in industrial plants. It also includes customizations for shutdown / layup, multiple pressures, mixed-metallurgy and aluminum feedwater systems, condensate polishing, units with ACC, special boiler types and with poor makeup. [TGD11-19](#)

Freely available and downloadable on IAPWS website www.IAPWS.org


33

Please do not add FFS if your HP Evaporator looks like this and/or has corrosion reaction products

(use the IAPWS Deposit Map to make an assessment)



2023 Assessment
Total Loading ~65 mg/cm²




IAPWS Deposit Map


34

or you might end up with an HP Evaporator like this

(2x1 Triple Pressure HRSG, Operating on AVT(O) with FFA (polyamine) added)



(Please use the IAPWS Deposit Map to make assessment before application of FFS)



Multi-laminated scale – UDC* rapid process



Embrittled Material

IAPWS Deposit Map



35

or like this: HP Evaporator Heavy Deposits and Failure

Double Pressure HRSG (9 and 0.5 MPa). HTF after FFAP Application without thorough upfront review (such as IAPWS Section 8)



Severe Under-deposit Corrosion (UDC)* in typical multi-laminated morphology. But no material degradation (voids)




* Perhaps a new variant*

SLIDE 16

36


And beware of Increasing Fossil Waterwall Deposits after FFS Application (without detailed up-front Section 8 FFS TGD review)

Fossil Boiler, 2500 psi, 276,000 hrs Chemistry AVT(O), FFP and PT. Loading is 177 g/ft² (190 mg/cm²)



37

Beware of Increasing HP Evaporator Deposits after FFS Application (without detailed up-front review)



38

Some Final Thoughts on “corrosion” in ACC

(Based on work conducted in Australia, Canada, Chile, China, Cote d'Ivoire, Dubai, India, Ireland, Mexico, Qatar, Abu Dhabi, South Africa, Trinidad, UK and US)


Increasing condensate pH to 9.8 will gradually eliminate the FAC damage at the tube entries and iron levels will reduce to international (IAPWS) suggested levels (5 - 10 ppb) at CPD. Documented by a decreasing DHACI. FFS sometimes will work but not sufficient detailed documentation of ACC before and after application and currently no understanding of/for improvement using the wide range of FFS.

Damage on cross members is not “arrested” as quickly by increasing pH. Is this LDI caused by the larger droplets leaving the PTZ of the LP Steam Turbine? Depth of damage down into ACC tube needs investigation? FFS appears in some cases to arrest FAC/Corrosion in the two-phase environments of an ACC.

Much care is required when using FFS for possible problems in remainder of plant (boiler/HRSG tube failures, deposits, drums, valves, etc). Problems observed in the wide range of FFS supplied (FFA and FFP).

Use of the IAPWS Decay Map can show definite improvement or not.

39



Summary

- Some aspects relate to (LT Two-phase) FAC**
 - Adjacent black and white areas in severe turbulent areas
 - Increasing local pH reduces damage
- But some aspects don't** (normal FAC scalloped appearance and white areas on cross members is probably LDI)
- Environment is known and has been measured**
 - Two-phase mixture formed in PTZ of the steam turbine well understood
 - Concentrating liquids on PTZ surfaces (Higher in chloride/sulphate, organics)
 - Lower in pH (0.5) and very low in dissolved oxygen (close to zero) on ACC surfaces
- “Arrested” two-phase FAC areas turn red slowly**
 - ACC Mechanism is thus not totally understood & what are amines/FFS doing?
 - Red coloration is known to form during shutdown (not during operation)
- Results from a number of plants indicate increased Al levels in turbine and drum deposits**
 - This may result from initial operation

Structural Integrity Associates, Inc.

40



IAPWS Technical Guidance Documents for Fossil and Combined Cycle Plants & with ACC

- **Procedures for the Measurement of Carryover of Boiler Water and Steam (September 2008).** This document includes the procedures to measure carryover from drum boilers to assist in preventing steam turbine failure/damage. Carryover
TGD1-08
- **Instrumentation for monitoring and control of cycle chemistry for the steam-water circuits of fossil-fired and combined-cycle power plants (June 2024).** This document includes a table that can be used to determine the minimum key level of instrumentation required for any fossil or combined cycle/HRSG plant. Also addresses fast and/or frequently started units. Instrumentation
TGD2-09(2024)
- **Volatile treatments for the steam-water circuits of fossil and combined cycle / HRSG power plants (July 2015).** This document includes the basis for AVT and OT for all plants with customization for plants with ACC and using ammonia and amines. Added guidance for fast and/or frequently started units. Volatile Treatments. AVT and OT
TGD3-10(2015)

Freely available and downloadable on IAPWS website www.IAPWS.org

41



IAPWS Technical Guidance Documents Fossil and Combined Cycle Plants & with ACC

- **Phosphate and NaOH treatments for the steam-water circuits of fossil and combined cycle / HRSG power plants (Oct 2015).** This document includes the basis for selecting the optimum boiler/HRSG evaporator water treatment for (phosphate and NaOH treatments) for all plants with drum units. Phosphate & NaOH. PT & CT
TGD4-11(2015)
- **Steam Purity for Turbine Operation (Sept 2013).** This document covers guidance for a wide range of turbines (fossil, nuclear, industrial, geothermal, etc) and failure mechanisms. It includes customizations for plants using amines and with carbon dioxide. Steam Purity
TGD5-13
- **Corrosion Product Sampling and Analysis (May 2014).** This document covers the optimum procedures and techniques for sampling and monitoring total iron and copper. Includes a table of achievable Fe/Cu levels for plants including those with ACC. Corrosion Products
TGD6-13(2014)

Freely available and downloadable on IAPWS website www.IAPWS.org

42



IAPWS Technical Guidance Documents Fossil and Combined Cycle Plants & with ACC

- **HRSG HP Evaporator Sampling for Internal Deposit Identification (Sept 2016).** This document includes the locations where to take samples from HGP and VGP HRSGs, how to analyze the samples, and an IAPWS map to assist in determining whether the HRSG HP evaporator needs to be chemically cleaned. HRSG HP Evap Deposits
TGD7-16
- **Application of FFS in Fossil, Combined Cycle and Biomass Plants (Revision October 2019).** This document covers optimum application guidance for FFA / FFAP / FFP in all-ferrous plants. It also includes customizations for shutdown / layup, multiple pressures, mixed-metallurgy feedwater systems, condensate polishing, and units with ACC. Film Forming Substances
TGD8-16(2019)
- **Air In-leakage (Sept 2018).** This document covers guidance for the monitoring and control of AIL for a wide range of fossil, biomass, nuclear, and industrial plants including those with ACC. The major performance and cycle chemistry aspects are included. Air In-Leakage
TGD9-18

Freely available and downloadable on IAPWS website www.IAPWS.org

43



IAPWS Technical Guidance Documents Fossil and Combined Cycle Plants & with ACC

- **Application of FFS in Industrial Steam Generators (October 2019).** This document covers optimum application guidance for FFA / FFAP / FFP in industrial plants. It also includes customizations for shutdown / layup, multiple pressures, mixed-metallurgy and aluminum feedwater systems, condensate polishing, units with ACC, special boiler types and with poor makeup. FFS Industrial Plants
TGD11-19
- **Chemistry Management in Generator Water Cooling (October 2019).** This document covers guidance for all generators with water-cooled windings. The high - and low - oxygen chemistries for operation and shutdown are included. Generators
TGD10-19

Freely available and downloadable on IAPWS website www.IAPWS.org

44



Resources for all areas of water and
steam

Freely available and downloadable on IAPWS website

- www.IAPWS.org

Please give full attribution to IAPWS