

Unrivaled performance. Not a slogan. A standard.

Programmatic Corrosion Mitigation in ACCs Using Anodamine

**ACCUG Annual Meeting: 7/30/2024** 

**Brian Courtright** 

**Jeff Demattos** 



#### Installation Information

- Four Identical H-Class 1x1 CCGT
  - Two Sites
- Triple Pressure SALP HRSGs
- 2300 PSIG / 1050 F Main Steam
- Air Cooled Condenser
- 2016 Commercial Operation
- Baseload
- Chemistry Evolution
  - o **2017-2018:** Raised pH set points
    - > 9.8 in FW
  - o **2019:** OLDA vs. Anodamine side by side trial at plant 1
  - o **2020:** OLDA filming amine trial

As of 2021 all units are running Anodamine AVT(O) with Ammonia



#### Severe ACC Corrosion

#### Chemistry was root cause of these issues

- Majority of ACC tube inlets were DHACI 3/4 and DHACI B/C in the lower ducts
- Plugged condensate, feed pump, and main/reheat strainers
  - Plant shutdown to clean out
- Bound up main and reheat control valves
- False trips due to plugged level sensors
- Stuck attemperation valves/no steam temp control
- Solid particle erosion
  - High pressure drains
    - Globe valves turning into toothpicks
    - Ruptures of drain header
    - Collapse of drain header standpipe
  - Service valves rebuilt 2x per year
  - Steam turbine degradations

Over 2000 hours of lost availability in the first 3 years of operation!
















# **Trial Goal:** Decrease iron corrosion transport

## Trial Results - Unit 10 Total Iron








Unit 10 Sample Locations

	Unit 10 Total Ire	on Values (ppb)	% Decrease		
	Historical	OLDA Trial	Anodamine	Anodamine vs Historical	Anodamine vs OLDA
Condensate	27	18	5	81%	72%
LP Drum	137	42	11	92%	74%
IP Drum	19	30	2	89%	93%
HP Drum	5	6	1	80%	83%

## Trial Results - Unit 20 Total Iron



#### **Unit 20 Total Iron Values**




Unit 20 Sample Locations

Unit 20 Total Iron Values (ppb)				% Decrease	
	Historical	OLDA Trial	Anodamine	Anodamine vs Historical	Anodamine vs OLDA
Condensate	10	12	4	60%	67%
LP Drum	175	<u>434</u>	4	98%	99%
IP Drum	47	<u>527</u>	2	96%	100%
HP Drum	11	67	3	73%	96%

## Millipore Sample - OLDA vs Anodamine Trial








**Anodamine** 

## Total Iron - Millipore





#### **Before Anodamine**




#### **After Anodamine**



#### ACC:Before and After Anodamine



**OLDA-type FFA** 







**DHACI 4** 

#### **AVT-O Anodamine**










**DHACI 1/2** 

#### ACC:Before and After Anodamine



**OLDA-type FFA** 








**DHACI 4** 

#### **AVT-O Anodamine**










**DHACI 1/2** 









**DHACI C** 

**DHACI A/B** 








**DHACI C** 








**DHACI B** 








**DHACI C** 








**DHACI C** 

## LP Steam Turbine








#### SPE and Anodamine

ANODAMINE

- Both stations (identical units) have a history of solid particle erosion (SPE) on HP steam turbine equipment, deterioration in turbine performance and deposit causing sticking valves with traditional AVT-O treatment. Root cause was determined to be steam oxide growth and exfoliation.
- OLDA treated units continued to have steam oxide growth and exfoliation issues
- Since Anodamine treatment, exfoliation and related issues have disappeared
- 1 unit had an Anodamine pump issue and did not dose for several months
  - O Exfoliation caused a reheat bypass valve failure in 4/2023
  - Once Anodamine dosing was corrected there has not been any additional issues



#### FFA Risks




#### Gunk balls/Slime Trail

- Found in the TED and **are still present today**
- Caused daily plant shutdowns due to clogging of condensate pump strainers
  - 16,000 MWh were lost!

#### Online sensors

- Online pH measurements
  - Doesn't match conductivity
- Sodium analyzers



#### 2020 Inspection - TED





#### 2025 Inspection - TED





## 16,000 MWh Lost Due to Fouled Strainers - OLDA




## Condensate strainers were plugging up after gunk balls were noticed

- After fall 2020 outage condensate pump strainers were plugging daily
- Daily **50% load reductions**
- All units switched to Anodamine on March 2021
- Plugging stopped 3 weeks after switching to Anodamine








**Load Decrease** 

## pH is Not Enough








#### **Anodamine Success**

- Anodamine was able to reduce total iron by
  ~80%
- Plant reliability at 100%
  - No shutdowns due to corrosion related issues or failures
- No negative side effects
  - Online instrumentation
  - No gunk balls
  - No increase is CC or DCACE
  - Non-toxic
- ACC tube inlets corrosion index improved from a 4 to a 1-2
- Lower ducts improved from a B-C to an A





## Questions